

**WASTE MANAGEMENT**

4 Liberty Lane West
Hampton, NH 03842

March 4, 2011

Ms. Linda Roberts
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051



RE: Waste Management of Connecticut, Inc. – New Milford Landfill
Connecticut Siting Council Annual Report

Dear Ms. Roberts,

Pursuant to and to the extent required by the Connecticut General Statute §16-50r, Waste Management of Connecticut, Inc. (WMCT hereby submits the following information requested for the New Milford Landfill:

1. **A tabulation of estimated peak loads, resources and margins for each year.** WMCT operates a Class I renewable energy source through the collection of landfill gas and combustion in three (3) reciprocating engines each with a generator rated at 820 kilowatts. The combined output of 2.5 MW was maintained at a relatively high operating efficiency during the past calendar year.

2. **Data on energy use and peak loads for the five preceding calendar years.**

	Peak			
	Load	Energy Produced	Energy Used	Energy Sold
<u>Year</u>	<u>(MW)</u>	<u>(kW-hrs)</u>	<u>(kW-hrs)</u>	<u>(kW-hrs)</u>
2006	2.5	13,755,000	3,746,220	10,008,820
2007	2.5	8,639,400	2,676,860	5,962,540
2008	2.5	11,439,711	564,789	10,874,922
2009	2.5	16,739,804	814,868	15,924,936
2010	2.5	15,082,868	672,386	14,410,482

3. **A list of existing generating facilities in service.** New Milford is the only generating facility in Connecticut operated by WMCT.
4. **A list of scheduled generating facilities for which a property has been acquired, for which certificates have been issued and for which certificate applications have been filed.** None

From everyday collection to environmental protection, Think Green® Think Waste Management.

Ms. Linda Roberts

March 4, 2011

Page 2

5. A list of planned generating units at plant locations for which property has been acquired, or at plant locations not yet acquired, that will be needed to provide estimated additional electrical requirements, and the location of such facilities. None
6. A list of planned transmission lines on which proposed route reviews are being undertaken of for which certificate applications have already been filed. None
7. A description of the steps taken to upgrade existing facilities and to eliminate overhead transmission and distribution lines in accordance with the regulation sand standards described in section 16-50t. No upgrades are planned as the three LFG engines were recently installed in 2008.
8. For each private power producer having a facility generating more than one megawatt and from whom the person furnishing the report has purchased electricity during the preceding calendar year, a statement including the name, location, size and type of generating facility, the fuel consumed by the facility and the by-product of the consumption. Not applicable.

If you have any questions or need additional information, please contact me at (603) 929-5436.

Sincerely,

WASTE MANAGEMENT OF CONNECTICUT, INC.



Mark P. DeVine
District Manager

Enclosures (20 copies of Annual Letter Report)

cc: Michael Sullivan, WMCT
Albert Wilder, TRC